

10 July 2014



South Australia's electricity transmission specialist

# Renewables and Power System Security – lessons from South Australia

Future Grid Symposium 2014

Rainer Korte


Executive Manager Asset Management

[electranet.com.au](http://electranet.com.au)

# Presentation outline

- > Provide context of high levels of wind energy penetration in South Australia and recent trends
- > Present early results of an ElectraNet and AEMO study which is investigating the system security implications of high levels of wind generation in South Australia


# SA wind zones



Major wind zones



# SA installed wind capacity



Source: Alinta Energy submission to RET review, 16 May 2014


# SA wind penetration metrics

Metric	Value for SA
Total installed wind generation capacity at 30 June 2014	1477 MW
Maximum instantaneous wind generation (3 July 2014 at 10pm)	1270 MW (86% of capacity)
Energy penetration – ratio of annual wind energy to annual total energy demand	> 25%
Maximum instantaneous penetration (excluding exports) – maximum observed ratio of wind energy to demand (Wind generation of 1138 MW, SA demand 1122 MW and SA export 487 MW on 27 June 2014 at 5am)	101%
Maximum possible instantaneous penetration – ratio of installed capacity to minimum demand (978 MW on 20 April 2014 at 5am)	151%
Average possible instantaneous penetration – ratio of installed capacity to average demand (1532 MW in 2013-14)	96%

Source: ElectraNet data

# SA wind energy trends

- > Increasing probability of wind-dominated generation scenarios (>50% of generation mix)
- > Expected to increase in the future under favourable market and policy scenarios



Source: ElectraNet data

# Wind integration study

## Objective:

- > Identify potential system security limitations arising from high levels of wind generation in South Australia

## Study scope:

- > Evaluate power system operation against the following criteria...
  1. Minimum fault levels and short-circuit ratios
  2. Frequency control and fault ride-through assessment
  3. Reactive power support/ voltage control
  4. Small-signal stability/ system damping
  5. Transient stability
- > Consider a range of system operating conditions with high levels of wind and low levels of conventional synchronous generation

# Power system security criteria





No	Criterion	What is it?	Why does it matter?
1	Minimum fault levels, short-circuit ratio	Measure of power system capability/ strength at various connection points	Load voltage regulation, protection co-ordination, fault ride-through capability
2	Frequency control (system inertia)	Maintain system frequency within prescribed limits (inertia helps by virtue of stored rotational energy)	Frequency recovery required to maintain system stability
3	Reactive power support	Required to support real power transfer and stable system voltages	Voltage stability (both steady-state and transient)
4	Small-signal stability	Adequate damping of small oscillations on electrical network	Mechanical integrity of connected generators and the power system
5	Transient stability	Ability to recover from large system disturbances	Maintain security of plant and power system



# Operating conditions studied

- > Power system scenarios:
  - SA light demand (1100 MW to 1400 MW)
  - Low conventional/ synchronous generation (0-5 thermal units) online
  - High wind generation (up to 1500 MW)
- > Heywood Interconnector maximum import and export scenarios at current capacity (460 MW) and upgraded capacity (650 MW)
- > Range of contingencies considered including loss of the Heywood Interconnector between SA and Victoria

# Results – Fault levels




- All fault levels at or above the 2 kA minimum required for effective operation of protection systems even with no thermal units
- Adequate margins (>4 kA) on most 275/132kV buses, except on Eyre and York Peninsula.

# Fault levels and short-circuit ratios


- > All short circuit ratios were at the about 4 or above required for effective operation of protection and wind farm control systems
- > Good correlation obtained between static (steady-state) and dynamic fault currents

Example comparison between steady-state and dynamic fault current calculations



# System inertia and fault ride through


- > At least one thermal unit is required on-line to control frequency
- > SA is able to survive islanding under high import conditions with at least one thermal unit on-line (and under frequency load shedding);
- > Inertia contribution from SA Type 1 & 2 wind farm models observed which limits rate of change as well as depth of frequency excursion



# Reactive support/ voltage stability


- > No reactive support issues under high export conditions
- > Worst case condition is high import conditions with no thermal units – additional reactive support needed to maintain voltage stability)

Additional 100MVar reactive dispatched in limiting case with no thermal units to maintain positive Q-V margin



# Small signal stability

- > Sufficient system damping observed under maximum wind dispatch even with no thermal units – modes disappear with no thermal units
- > Inter-regional modes to be investigated further



Left shift in some intra-regional machine modes (improvement in damping) observed when reduce thermal units from 4 to 1

Further work to be undertaken to test and understand this outcome

## Summary of findings

- > Studies indicate that the South Australian power system can be operated securely at N-1 with high levels of wind generation
- > Most system security criteria were satisfied even with no thermal generating units on-line except...
  - Frequency control requires at least one thermal unit
  - Voltage stability under high SA import conditions requires at least one thermal unit or additional reactive dispatched
  - Transient stability/ overvoltage and voltage recovery under islanded conditions
- > No network and generation protection co-ordination issues were identified

## Summary of findings (cont.)

- > For credible contingencies, no issues with system frequency and voltage recovery post-fault (with at least one thermal unit)
- > For non-credible contingency involving loss of Heywood Interconnector, local SA frequency controls allow SA system frequency recovery to within Frequency Operating Standards (with at least one thermal unit)
- > Sufficient reactive support margins (when utilising all mitigation options including high voltage capacitor bank dispatch)
- > Sufficient system damping under maximum wind dispatch



## Next steps

- > Current studies expected to be concluded within next months with recommendations for further work
- > ElectraNet and AEMO to consider how results are communicated

10 July 2014



South Australia's electricity transmission specialist

# Renewables and Power System Security – lessons from South Australia

Future Grid Symposium 2014

Rainer Korte

Executive Manager Asset Management

[electranet.com.au](http://electranet.com.au)